

Certificate of constancy of performance,

0832-CPR-F0362

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

DF2000

(For full product details and conditions of use refer to appendix)

Produced by or for

Cooper Lighting and Safety

Wheatley Hall Road
Doncaster
South Yorkshire
DN2 4NB
United Kingdom

and produced in the manufacturing plant(s)

Cooper Lighting and Safety

Wheatley Hall Road
Doncaster
South Yorkshire
DN2 4NB
United Kingdom


This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-2:1997+A1:2006 and EN 54-4:1997+A1:2002+A2:2006

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 12 June 2014 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Wasantha Hunukumbure, Certification Manager
On behalf of BRE Global Limited
Date of issue: 12 June 2014
Issue number: 02

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR- F0362

DF2000 Analogue addressable 2 loop control and indicating equipment

Incorporating the following units:

PR202-50-2209 Power supply board

PR202-50-2206 Main motherboard

PR202-50-2205 Display board

Certified with the following options with requirements from EN 54-2:

7.8 Output to fire alarm device(s)

7.9.1 Output to fire alarm routing equipment

7.10.1 Output to automatic fire protection equipment (Type A)

7.11 Delays to outputs


7.12.3 Dependencies on more than one alarm signal (Type C)

7.13 Alarm counter

8.9 Output to fault warning routing equipment

9.5 Disablement of each address point

10 Test condition



Wasantha Hunukumbure, Certification Manager
On behalf of BRE Global Limited

Date of issue: 12 June 2014

Issue number: 02

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.