

# BRE Global Ireland

**Notified Body No. 2831**  
BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

## Certificate of constancy of performance

### 2831-CPR-F1140

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

#### CF3000 Intelligent Analogue Addressable 1-4 Loop Control and Indicating Equipment

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

**Eaton Electrical Systems Ltd**  
Wheatley Hall Road  
Doncaster  
South Yorkshire  
DN2 4NB  
United Kingdom

**Eaton Electrical Products Limited**  
Llantarnam Park  
Cwmbran  
Gwent  
NP44 3AW  
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

**EN 54-2:1997 + A1:2006 - Control and indicating equipment**  
**EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### **the constancy of performance of the construction product.**

This certificate was first issued on 06 August 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Engineer

Date of First Issue: 6 August 2020

Date of Issue: 6 August 2020

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)

## BRE Global Ireland

## Notified Body No. 2831

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland

T: +353 (0) 18824344

E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

### APPENDIX to Certificate of constancy of performance: 2831-CPR-F1140

#### CF3000 Intelligent Analogue Addressable 1-4 Loop Control and Indicating Equipment

Incorporating the following units:

ADF6 Back	Assembled back box
YPCB2153	Motherboard PCB
YPCB2147	PSU PCB
YPCB2148	2 Loop Card (2 off)
ADF6Screen	Touch Screen
YPCB2185	Complete Display + Micro PCB
ADF6 DISPCOVER	Display PCB Cover
ADF6FACIA	Front Moulding
ADF6PRINTDOOR	Printer Door Moulding
BAT-NP12-12	Batteries (2 off)
ADF6HINGE	Door Hinges

Incorporating the following optional modules:

ADF6OPFACIA	Optional Anti Tamper Cover
ADF6PRINTER	Printer
YPCB2187	Fire Brigade Interface
YPCB2137	Micro Display card
YPCB2319	Sounder loop card
YPCB2433	FRE/FPE loop card
YPCB2222	Loop splitter card
YPCB2145LED	LED board
YPCB2202	Single channel Network card
YPCBNCDRUL	Dual channel Network card

Certified with the following options with requirements from EN 54-2:

7.8	Output to fire alarm device(s)
7.9.1	Output to fire alarm routing equipment
7.10.1	Output to automatic fire protection equipment (Type A)
7.10.2	Output to automatic fire protection equipment (Type B)
7.11	Delays to outputs
7.12.3	Dependencies on more than one alarm signal (Type C)
7.13	Alarm counter
8.9	Output to fault warning routing equipment
9.5	Disablement of each address point
10	Test condition

*P. Halligan*

P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 6 August 2020

Date of issue: 6 August 2020

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)

## BRE Global Ireland

### Notified Body No. 2831

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland

T: +353 (0) 18824344

E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)

[www.breglobalireland.ie](http://www.breglobalireland.ie)

## APPENDIX to Certificate of constancy of performance: 2831-CPR-F1140

### Notes:

1. The scope of approval does not include the network functionality.
2. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.

*P. Halligan*

P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 6 August 2020

Date of issue: 6 August 2020

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)