

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F0857

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

MAH830 Intelligent Analogue Addressable Class P Heat Detector with Short Circuit Isolator

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Eaton Electrical Systems Ltd
Wheatley Hall Road
Doncaster
South Yorkshire
DN2 4NB
United Kingdom

and produced in the manufacturing plant(s):

SC Cooper Industries Romania SRL
Zona Industriala NV.
Str. III, NR 12
Arad
310510
Romania

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-5: 2000 + A1:2002 Heat Detectors
EN 54-17: 2005 Short Circuit Isolators

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 05 November 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager

Date of First Issue: 5 November 2020

Date of Issue: 5 November 2020

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 1

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie

www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0857

MAH830 Intelligent Analogue Addressable Class P Heat Detector with Short Circuit Isolator

Heat Classifications:

Class A1R

Class BS

Class CS **Sensitivities:**

Bases:

MAB800 Single contact standard analogue addressable mounting base¹

MABD Double contact standard analogue addressable mounting base²

Product Variants:

Variants:

MAH830 (Menvier)

FXN725 (JSB)

CAH330

COPH430

Variant Bases:

MAB800¹ (Menvier)

FXN720¹ (JSB)

CAB300¹

COPA800¹

MABD² (Menvier)

FXABD² (JSB)

CABD²



P Halligan, Certification Manager,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 5 November 2020

Date of issue: 5 November 2020

Issue number: 1

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie