

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F0621

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

CASB383WP-B Addressable Type A/B Wall Sounder/Beacon with Short Circuit Isolator

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

Eaton Electrical Systems Limited
Wheatley Hall Road
Doncaster
South Yorkshire
DN2 4NB
United Kingdom

Eaton Electrical Products Limited
Llantarnam Park
Cwmbran
South Wales
NP44 3AW
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-3: 2001 + A1: 2002 + A2: 2006 Sounders **EN 54-17: 2005 Short Circuit Isolators**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 24 September 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager

Date of First Issue: 24 September 2020

Date of Issue: 24 September 2020

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 1

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0621

CASB383WP-B Addressable Type A/B Wall Sounder/Beacon with Short Circuit Isolator

Addressable Type A/B Wall Sounder/Beacon with Short Circuit Isolator

Notes:

1) Meets the requirements of EN54-3: 2001 for the following tones:

- Continuous 984Hz
- Pulsed 984 / 0Hz pulse 1Hz
- Two Tone 644 / 984Hz @ 1 Hz cycle
- Bell Tone (This tone is not EN 54-3 approved)

2) The beacon functionality is not included within the scope of this approval



P Halligan, Certification Manager,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 24 September 2020

Date of issue: 24 September 2020

Issue number: 1

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie